

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 711..

Date : 04/04/2025

It is to certified that an inspection team headed by Mr. K.L. Dewangan, Asst. Engineer From Sub Division Bhatapara PHED inspected the The Aditya Birla Public School, P.O. Grasim Vihar, Village Rawan, Dist. Balodabazar – Bhatapara (C.G.) 493196 on 02/04/2025 and on the basis of Water Test Report (Attached) bearing No. SDWTL/PHED/BYT-003 Dated 04/04/2025 of Sub Divisional Water Testing Laboratory Bhatapara (PHED Lab) Certified that the The Aditya Birla Public School, Rawan has safe drinking water facilities for the students and members of staff of the institution. School also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/state/U.T. Govt.

This Certificate is valid till Date : 03/03/2026

Assistant Engineer
Signature with seal : *[Signature]*
Public Health Engg. Sub-Div.
BHATAPARA (Chhattisgarh)
Name : Mr. K.L. Dewangan
Designation : Asst. Engineer
Name & Address of the office/Department :
Sub Division Bhatapara (PHED) Patpar, C.G.

To,

The Aditya Birla Public School,
P.O. Grasim Vihar, Village Rawan,
Dist. Balodabazar-Bhatapara, (C.G.),
Pin Code - 493196

[Signature]
MANAGER
THE ADITYA BIRLA PUBLIC SCHOOL
PO GRASIM VIHAR, RAWAN-493196
Distt Baloda Bazar-Bhatapara (C.G.)

[Signature]
PRINCIPAL
THE ADITYA BIRLA PUBLIC SCHOOL
GRASIM VIHAR, RAWAN
BALODA BAZAR-BHATAPARA, C.G. 493196



Certificate No. - DWT-00326

Sub Divisional Water Testing Laboratory
 Public Health Engineering Department, Sub Division – Bhatapara
 Office of The Assistant Engineer PHED Campus, Patpar Bhatapara (C.G.) 493118
 (E mail - aephebyt@gmail.com)

Test Report (Drinking Water)

Report No. SDWTL/PHED/BYT- 003	Discipline	Chemical Testing	Group :	Drinking Water
Senders name & address : ABPS Rawan Balodabazar - Bhatapara (C.G.)	Senders letter No./Date	003/04.04.2025	Sampled by	ABPS Rawan
	Sample collection Date	04.04.2025	Sampling Plan & procedure	Sampling not done by Lab staff
	SDL receipt No.	003	SDL Receipt Date	04.04.2025
	Date of analysis Started	04.04.2025	Date of analysis completed	07.04.2025

Sample Details

Sr.N.	Sample I.D.	District /Block	City / Village	Habitation	Location/Source ID./GPS Identification
1.	003/009/04/25	Bhatapara	Rawan	-	Near of Aditya Birla Public School

Details of parameters their test method units and specification as per IS/APHA

Sr. N.	Parameters	Test method IS:3025/APHA 23rd ed.		Unit	As per IS-10500-2012 drinking water		Result Of Sample As Sr.No.										
		Method	Part No.		Acceptable Limit	Permissible Limit	1	2	3	4	5	6	7	8	9	10	
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	
1	PH	IS:3025	Part-II	pH scale	6.5 - 8.5	No Relaxation	8.20										
2	Turbidity	IS:3025	Part-10	NTU	1	5	1.8										
3	Colour	APHA 23rd ed	2120-B	Hazen	5	15	4										
4	Odour	IS:3025	Part-5	-	Agreeable	Agreeable	Agr										
5	Taste	IS:3025	Part-8	-	Agreeable	Agreeable	Agr										
6	Chloride as Cl ⁻	IS:3025	Part-32	mg/l.	250	1000	31.84										
7	Alkalinity as CaCO ₃	IS:3025	Part-23	mg/l.	200	600	128.76										
8	Hardness as CaCO ₃	IS:3025	Part-21	mg/l.	200	600	190.25										
9	Calcium as Ca ²⁺	IS:3025	Part-40	mg/l.	75	200	56.78										
10	Magnesium as Mg ²⁺	APHA 23rd ed	3500	Mg-B	mg/l.	30	100	11.80									
11	TDS	APHA 23rd ed	2540-C	mg/l.	500	2000	238.0										

1. The report should not be produced partly or full without approval signatory authority of legal purpose.
2. It is recommended that acceptable limit is to be implemented. Values in excess of those mentioned under "acceptable" render the water not suitable, but still may be tolerated in the absence of an alternative source but up to the limits indicated under the "permissible" limit in the absence of alternate source in column 7 above which the sources will have to be rejected.
3. The results refer only to tested samples and parameters.
4. Samples will be stored for a period of 10 days from date of issue of report.
5. This Lab does not hold any responsibility for variation in results for samples kept on hold for wants of clarification.
6. Results apply to the sample as received.
7. Sampling not done by Lab staff.

Chemist

Sub Divisional water Testing Laboratory
PHE Bhatapara- 493118

MANAGER
 THE ADITYA BIRLA PUBLIC SCHOOL
 PO GRASIM VIHAR, RAWAN-493196
 Distt Baloda Bazar-Bhatapara (C.G.)

PRINCIPAL
 THE ADITYA BIRLA PUBLIC SCHOOL
 GRASIM VIHAR, RAWAN
 BALODA BAZAR-BHATAPARA, C.G. 493196

Sub Divisional Water Testing Laboratory
 Public Health Engineering Department, Sub Division – Bhatapara
 Office of The Assistant Engineer PHED Campus, Patpar Bhatapara (C.G.) 493118
 (E mail - aephebyt@gmail.com)

Test Report (Drinking Water)

Report No. SDWTL/PHED/BYT/- 003	Discipline : Chemical Testing	Group : Drinking Water	
Senders name & address : ABPS Rawan Balodabazar – Bhatapara (C.G.)	Senders letter no./Date 003/04.04.2025	Sampled by Sampling Plan & procedurz	ABPS Rawan Sampling not done by Lab staff
	Sample collection date 04.04.2025		
	SDL receipt no. 003	SDL Receipt Date 04.04.2025	
	Date of analysis started 04.04.2025	Date of analysis completed 07.04.2025	

Sample Details

Sr.N	Sample I.D.	District /Block	City / Village	Habitation	Location/Source ID/GPS Identification
1	2	3	4	5	6
1.	003/009/04/25	Bhatapara	Rawan	-	Near of Aditya Birla Public School

Details of parameters their test method units and specification as per IS/APHA

Sr. N.	Parameters	Test method IS:3025/APHA 23rd ed.		Unit	As per IS-10500-2012 drinking water		Result Of Sample As Sr.No.									
		Method	Part No.		Acceptable Limit	Permissible Limit	1	2	3	4	5	6	7	8	9	10
1	Residual chlorine	-	-	mg/l.	0.2	1.0	0.0									
2	Spec. Conductivity	IS:3025	Part-14	μmho/cm	-	-	476.0									
3	Bacteriological	-	-	CFU/100ml	Nil	Nil	Nil									
4	Fluoride	APHA	4500-F-C	mg/l.	1.0	1.5	0.37									
5	Nitrate	APHA	4500-NO ₃ -B	mg/l.	45	45	3.61									
6	Iron	APHA	3500-Fe-B	mg/l.	0.3	1.0	0.80									

1. The report should not be produced partly or full without approval signatory authority of legal purpose.
2. It is recommended that acceptable limit is to be implemented. Values in excess of those mentioned under "acceptable" render the water not suitable, but still may be tolerated in the absence of an alternative source but up to the limits indicated under the "permissible" limit in the absence of alternate source in column 7 above which the sources will have to be rejected.
3. The results refer only to tested samples and parameters.
4. Samples will be stored for a period of 10 days from date of issue of report.
5. This Lab does not hold any responsibility for variation in results for samples kept on hold for wants of clarification.
6. Results apply to the sample as received.
7. Sampling not done by Lab staff.

[Signature]
 Chemist
 Sub Divisional water Testing Laboratory
 PHE Bhatapara - 493118

[Signature]
MANAGER
 THE ADITYA BIRLA PUBLIC SCHOOL
 PO GRASIM VIHAR, RAWAN-493118
 Distt Baloda Bazar-Bhatapara (C.G.)

[Signature]
PRINCIPAL
 THE ADITYA BIRLA PUBLIC SCHOOL
 GRASIM VIHAR, RAWAN
 BALODA BAZAR-BHATAPARA, C.G. 493118