

FIRE SAFETY CERTIFICATE

No. FSCA/O/RFOBHAV/2024/00073804/R1

Dated: 10.08.2024

Certified that the The Aditya Birla Public School GCW Township (name of the building or premises) at GCW Township Kovaya Taluka Ratala Dist Amreli Gujarat-365541 (address) comprised of Ground Floor basement(s) and First Floor (upper floors) owned/occupied by The Aditya Birla Public School, Kovaya (name of the Institution) have complied with the fire prevention and fire safety requirements in accordance with rule of State/UT Fire Service Rules, and verified by the officers concerned of Fire Service on 10.08.2024 (date of inspection) in the presence of Mr. Indrajit Padhye, Principal, ABPS, Kovaya (name and addresses of the Manager/Secretary or his representative) and that the building/premises is fit for occupancy class Nursery to Class XII with effect from 10.08.2024 for a period of Two (2) years in accordance with rule and subject to compliance of the conditions.

Issued on 10.08.2024 at ABPS GCW Township Kovaya, UTCL by

* Strike out whichever is not applicable.

Signature with Seal : Name : Parashuram SanjaykumarDesignation : FSC - G1

To

The Aditya Birla Public School, KovayaGCW Township Kovaya, UltraTechTaluka-Ratala Dist-Amreli, Gujarat

(Name & Address of the Institution)

ENDORSEMENT

The No Objection Certificate issued by Fire Service stand cancelled and annulled due to


(reasons to be recorded).

(Name and designation of the authorized signatory)



Principal
The Aditya Birla Public School
Gujarat Cement Works
Kovaya - 365 541
Dist. Amreli, Gujarat

For, Aditya Birla Education Trust



Authorised Signatory





rfo-bvr@gujarat.gov.in



FORM B 13.3

FIRE SAFETY CERTIFICATE RENEWAL (FSCR)

(See Rule 25)

Fire Safety Certificate Approval (FSCA) No. FSCA/O/RFOBHAV/2024/00073804
FSC Safety Certificate Renewal (FSCR) No. FSCA/O/RFOBHAV/2024/00073804/R1

Date: 10/08/2024

Building Occupancy/Category: Educational (non-residential)

To,

VALMIK TANGA BHADANE

Kovaya Kovaya Kovaya RAJULA Amreli 365541

Fire Region: Bhavnagar RFO

Mobile No: 9714804169 Email ID: gcw-kovaya.school@adityabirla.com

This has reference to your Application No. 2024/00075408 dated 29/07/2024 for Fire Safety Certificate Renewal (FSCR) for the building/premise **The Aditya Birla Public School (name of the Building/ Project)**, as per below mentioned details:

1. TP Number:
2. FP Number:
3. Survey Number:
4. Village Name: Kovaya
5. Name of Block(s): Aditya Birla public school

The building/premise was inspected on **10/08/2024** and all fire prevention, life safety and fire protection measures provided were found to be in proper and effective working condition. There are no changes in building/premise use or occupancy or in building design or structure.

Further, the following activities (as applicable) have been carried out towards meeting requirements of GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 as amended, or the then applicable GDCR:

1. Emergency drill was carried out on **10/08/2024**
2. Six monthly inspection was done on **10/08/2024**

The Fire Safety Certificate is renewed for a period of **two (2)** years upto **10/08/2026** in accordance with GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 and their amendments.



Digitally Verified

Digitally verified by: Panchani Sanjaykumar Bhikhambhai
Fire Safety Officer - General (FSO-G)
2021/001330

Date: 10/08/2024
Time: 04:08 PM



FSCA/O/RFOBHAV/2024/00073804/R1

This is a digitally verified certificate, hence doesn't require physical signature. To validate authenticity of this certificate, scan the QR code or search the certificate details in appropriate section at www.gujfiresafetycop.in.

Please note that, apart from renewal, the building needs to be inspected every six months and a mock fire and emergency drill also needs to be conducted every six months. If there is a delay in scheduled inspection or mock drill, penalty shall be imposed. The Fire Safety Certificate renewal should be done timely after two years to avoid penalties.