



OFFICE OF THE DISTRICT FIRE OFFICER
Karnataka Fire & Emergency Services
Haveri Fire Station, Haveri-581110.



email Id:- haveridfo@gmail.com

Telephone:08375-232666/9480823663

No:05/R.C.C/DFO/ HAVERI/2026.

Dated:02.02.2026.

To,

The Principal,
Grassim Education Society,
Aditya Birla School,
Situated at Sy No:29, Kodiyal Village,
Ranebennur Taluk Haveri District-581123
School Dis Code:29111406405/29111406407/29111413801

Sir,

Sub: Issue of Renewal of " **Compliance Report**" with respect to fire prevention, fire fighting and evacuation measures maintained:required at " **Grassim Education Society, Aditya Birla School, Situated at Sy No:29, Kodiyal Village, Ranebennur Taluk Haveri District-581123.**

Ref:- 1. No:82/FSSR/FSR/College/RFO/DR/2022 Dated:17-06-2022.
2. Your application Dated:30-12-2025.
3. No:06/FSR/LRB/CC/RANEBENNUR/2026 Dated:02-02-2026

With reference to the subject cited above, "Fire Safety Recommendation" was issued wide reference (1) to the at " **Grassim Education Society, Aditya Birla School, Situated at Sy No:29, Kodiyal Village, Ranebennur Taluk Haveri District-581123**". with maintained recommended Fire precautionary measures.

The management at " **Grassim Education Society, Aditya Birla School, Situated at Sy No:29, Kodiyal Village, Ranebennur Taluk Haveri District-581123**". School Dis Code: had requested for the compliance report from our department. In this regard the building was inspected by FSTO RANEBENNUR 14-01-2026 & verified all the precautionary measures. And as per reference (3) Submitted the report and recommended to issue of Renewal of Compliance Certificate.

Under the above circumstances the Karnataka Fire & Emergency Services Department is issuing the Renewal of " **Compliance Certificate**" to of " **Grassim Education Society, Aditya Birla School, Situated at Sy No:29, Kodiyal Village, Ranebennur Taluk Haveri District-581123**". School Dis Code: 29111406405/29111406407/29111413801. Subject to proper maintenance of fire fighting system in good working condition and at-least 40% of employees should be trained in basic fire fighting at our R.A Mundkur Fire & Emergency Academy, Bannerghatta road, Bengaluru.

This Clearance Certificate is valid till Dated:01-02-2028 and it is renewable.


Principal
The Aditya Birla Public School
KUMARAPATNAM-581 123
(Near : Harihar)
Ranebennur Tq. Haveri Dt.



TRUE COPY
Attested

Yours faithfully

District Fire Officer
Karnataka Fire & Emergency Services
Haveri Dist