

Government of Andhra Pradesh

A.P. State Disaster Response and Fire Services Department

Periodical Renewal Fire Certificate

From:
District Disaster Response & Fire
Officer, Nandyal District.

To:
District Educational Officer,
Nandyal District.

File No: 29386/NDL/DFO/2025, Date: 23/12/2025

Occupancy NoC RC Number: 3125

Sir,

Sub: Andhra Pradesh State Disaster Response and Fire Services Department - Periodical Fire Certificate to the existing Non Multi Storeyed Building of **THE ADITYA BIRLA PUBLIC SCHOOL**, represented by **ULTRATECH CEMENT LIMITED APCW, Sy.No.272 C/o ULTRATECH CEMENT LIMITED THUMMALAPENTA VILLAGE AND POST KOLIMIGUNDLA MANDAL NANDYAL DT** - Regarding.

- Ref:
1. G.O.Ms.NO.218 Home (Prisons & Fire) Department, Dated.22-12-2023
 2. This Office Delegation of Powers Re.No.3350/Audit/NOC/2012, Dated.02-05-2023.
 3. This Office NOC for Occupancy Re No. 3125, Dt.05/01/2021
 4. Renewal NOC For Occupancy 3125, Dt.21/12/2019
 5. Online Application for Renewal NOC of **ULTRATECH CEMENT LIMITED APCW, Sy.No.272 C/o ULTRATECH CEMENT LIMITED THUMMALAPENTA VILLAGE AND POST KOLIMIGUNDLA MANDAL NANDYAL DT** - Inspection report called for Regarding.
 6. Online Inspection Report submitted by Officers of this Department on 23-12-2025.

-- x --

The Management of **THE ADITYA BIRLA PUBLIC SCHOOL**, represented by **ULTRATECH CEMENT LIMITED APCW, Sy.No.272 C/o ULTRATECH CEMENT LIMITED THUMMALAPENTA VILLAGE AND POST KOLIMIGUNDLA MANDAL NANDYAL DT** has requested to issue Periodical Fire Certificate duly remitting the Fire Precautionary fee for Rs.27790/- vide challan No. 91285323342925, Dated 15/12/2025 at SBI, ONLINE.

THE ADITYA BIRLA PUBLIC SCHOOL

1. This certificate is being issued as per G.O.Ms.No:218,Home(Prisons & Fire),Dt:22-12-2023
2. The No Objection Certificate for Occupancy was issued vide reference cited (3) and the Management has also obtained Periodical Renewal Fire Certificate for vide reference 4th cited to the existing Non Multi Storeyed Building.
3. The Officers of the department have recommended to issue The Periodical Renewal Fire Certificate **ULTRATECH CEMENT LIMITED APCW Sy.No.272 C/o ULTRATECH CEMENT LIMITED THUMMALAPENTA VILLAGE AND POST KOLIMIGUNDLA MANDAL NANDYAL DT**, subject to the following conditions.

Sl	As Builder	As Occupant	As Security Personnel
1	All the fire protection arrangements shall be maintained in good condition as seen during inspection.	All the escape/exit routes shall not be kept locked/blocked or encroached	All the occupants must know the correct method of operation of the fire fighting system installed.
2	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibilities of the management.	All occupants shall be trained to operate the fire safety equipments during emergency.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.
3	Addition / alteration, if any in the building may be verified by building authority.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.	All security personnel shall be trained to operate the fire safety equipments during emergency.

4 This is Only for Fire Safety Point of View.	Raise the alarm if the fire cannot be controlled; Evacuate the area completely at once with nearest safe exit.	Attack the fire using available fire equipment only if you feel capable of controlling. If not, take all steps to isolate the area by closing doors and windows.
---	--	--

The applicant/management must train 40% of their total work force on 3 days Basic Firefighting Course under AP Fire Services and Civil Defence Training Institute, Sattenapalli or Regional Training Centres of the Department.

4. This Periodical Renewal Fire Certificate is valid from 23/12/2025 to 22/12/2026.

5. The Responsibility/liability of the owner/occupier or both to maintain Fire safety measures in good condition in all times, in accordance with AP Fire safety Act 1999 and Rules, 2006.

6. Challan Info:

Challan Number	Challan Date	Challan Amount
91285323342025	15.12.2025	27790.00

The following deficiencies/suggestions are identified by the officers of the department and needs to be attended to by the management.

- 1) This Renewal NOC is issued form Fire Safety Point of view only basing on Recommendation of the inspection Committee and this Renewal NOC is not for Claiming proprietary or ownership rights further, in case of any deviation Noticed with respect to this Renewal NOC after Issuance of this Renewal NOC, The same Renewal NOC shall be liable for cancellation at any time.
- 2) The Management has to maintain Fire Safety Measures and other installations in Good working condition at all times and the Responsibility of Fire Fighting Equipment Maintenance lies with the management as seen & tested by the Committee at the time of inspection.
- 3) This Renewal NOC is valid for Three Years only and it is the responsibility of the Builder/ owner to apply for renewal of No Objection certificate, duly Remitting the user Charges G.O.Ms.No.169, Home (prisons & Fire Service) Department, Dt.19.12.2019. Two Months before expire of this No Objection Certificate.

Anil Kumar
Principal
The Aditya Birla Public School
Thummalapenta (VII) - 518 123
Kolimigundla (Mdl), Nandyal Dt. (A.P)
Phone : 08558 288143
Aff No - 130154

Your Sincerely,
[Signature]
District Disaster Response &
Fire Officer, Nandyal District.

Copy to Management ULTRA TECH CEMENT LIMITED APCW, General Manager, Administration, UltraTech Cement Ltd., Kolimigundla Mandal, Nandyal District.

Copy to Station Fire Officer Concerned.