

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 2078

Date : 18/03/24

It is certified that an inspection team headed by Ram Singh
(Name of Officers with designation) from PHED Pindwara
(Name of Department/Office) inspected the ADITYA BIRLA PUBLIC SCHOOL NATHDWARA,
Aditya Nagar, Pindwara, Dist. Sirohi on 18-03-2024 and found that the ADITYA BIRLA
PUBLIC SCHOOL NATHDWARA has safe drinking water facilities for the students and members
of staff of the institution and is maintaining the hygienic sanitation condition in the school building &
the campus as per the norms prescribed by the Central / State / U.T Govt.

The above valid for a period of one year w.e.f. 18.03.2025

Signature with Seal :



सहायक अभियन्ता
जन स्वा अभि. विभाग
उपाध्यक्ष-पिण्डवाड़ा

Name : _____

Designation : _____

To

Aditya Birla Public School Nathdwara
Aditya Nagar, Pindwara
Dist. Sirohi, Rajasthan
PIN 307031



OFFICE OF THE JUNIOR CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT, LABORATORY ABU ROAD
REPORT OF THE CHEMICAL EXAMINATION OF WATER

No. Lab/Tech(Chem)/2016-2017/ 1732-1733
 To,

Assistant Engineer
P.H.E.D. Sub Division
Pindwara

Dated : 7/3/2024

District: Sirohi
Block: Pindwara

Reference : Your Letter No. **Lab sampling**
 Date of Receipt : **05/03/2024**

Dated: **05/03/2024** Name of Sample Taker: **Lab staff**
 Ref ID: **160**

Source	Treated Water				
Source Location	Aaditya Birla Public School Nathdwara				
Village/Town	Pindwara (Urban)				
Habitation	Pindwara (Urban)				
Village Code No.	0				
Date of Collection	05/03/2024				
Date of Examination	06/03/2024				
Lab. Sample No.	1801				

Note :- All results Except pH are in mg/L

1 pH	7.12				
2 Turbidity (NTU)	Clear				
3 Colour	None				
4 Odour	None				
5 Temperature (°C)	25				
6 Total Alkalinity (as CaCO ₃)	50				
7 Total Hardness (as CaCO ₃)	70				
8 Calcium Hardness (as CaCO ₃)	40				
9 Magnesium Hardness (as CaCO ₃)	30				
10 Chloride (as Cl ⁻)	30				
11 Sulphate (as SO ₄ ²⁻)	-				
12 Nitrite (as NO ₂ ⁻)	0				
13 Nitrates (as NO ₃ ⁻)	10.53				
14 Fluoride (as F ⁻)	0.166				
15 Total Dissolved Solids	162				
16 Iron	-				
17 Residual Chlorine					

No. Lab/Tech(Chem)/2016-2017/

Copy to:

- 1 The Chief Chemist, Public Health Engineering Department, Rajasthan, Jaipur.
- 2 The Executive Engineer, PHED Division Sirohi/Abu Road

3 *The Principal A BPS Nathdwara, Pindwara*

Junior Chemist
PHED Lab Abu Road
P.H.E.D. Lab
ABU ROAD

Junior Chemist
Junior Chemist
P.H.E.D. Lab
ABU ROAD